

ASME EA-3–2009

Energy Assessment for Steam Systems

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers



Copyright © 2010 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



ASME EA-3-2009

Energy Assessment for Steam Systems

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**



Copyright © 2010 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: January 22, 2010

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda issued to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME EA Committee may be published as Cases. Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org> as they are issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2010 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in the U.S.A.

Copyright © 2010 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



CONTENTS

Foreword	iv
Committee Roster	v
Correspondence With the EA Committee	vi
1 Scope and Introduction	1
2 Definitions	2
3 References	3
4 Organizing the Assessment	3
5 Conducting the Assessment	5
6 Assessment Data Analysis	9
7 Report and Documentation	9
Figure	
1 Assessment Method	6
Nonmandatory Appendix	
A Key References	13



FOREWORD

This document provides a standardized framework for conducting an energy assessment for steam systems, hereafter referenced as an “assessment.” A steam system is defined as a system containing steam generator(s) or other steam source(s), a steam distribution network, and end-use equipment. Cogeneration and power generation components may also be elements of the system. If steam condensate is collected and returned, the condensate return subsystem is a part of the steam system. Assessments involve collecting and analyzing system design, operation, energy use, and performance data and identifying energy performance improvement opportunities for system optimization. An assessment may also include additional information, such as recommendations for improving resource utilization, reducing per unit production cost, reducing life cycle costs, and improving environmental performance related to the assessed system(s).

This Standard provides a common definition for what constitutes an assessment, for both users and providers of assessment services. The objective is to provide clarity for these types of services which have been variously described as energy assessments, energy audits, energy surveys, and energy studies. In all cases, systems (energy-using logical groups of industrial equipment organized to perform a specific function) are analyzed through techniques, such as measurements, resulting in the identification, documentation, and prioritization of performance improvement opportunities.

This Standard sets the requirements for conducting and reporting the results of an assessment that evaluates the entire system, from energy inputs to the end use utilization of these inputs. An assessment that complies with this Standard need not address each individual system component or subsystem within an industrial facility with equal weight; however, it must be sufficiently comprehensive to identify the major energy efficiency opportunities for improving the overall energy performance of the system. This Standard is designed to be applied primarily at industrial facilities, but many of the concepts can be used in other facilities such as those in the institutional and commercial sectors.

The Standard is part of a portfolio of documents designed to assist in improving the efficiency of industrial facilities. Initially, four assessment standards are being developed for compressed air, process heating, pumping, and steam systems. Other related existing and planned efforts to improve the efficiency of industrial facilities include:

(a) ASME guidance documents for the assessment standards, which provide rationale for the technical requirements of the assessment standards and give technical guidance, application notes, alternate approaches, tips, techniques, and rules-of-thumb.

(b) A certification program for each assessment standard that recognizes certified practitioners as individuals who have demonstrated, via a professional qualifying exam, that they have the necessary knowledge and skills to properly apply the assessment standard.

(c) An energy management standard, “A Management System for Energy, ANSI/MSE 2000:2008,” which is a standardized approach to managing energy supply, demand, reliability, purchase, storage, use, and disposal, and is used to control and reduce an organization’s energy costs and energy-related environmental impact. Note: This ANSI standard will eventually be superseded by ISO 50001, now under development.

(d) An ANSI-accredited measurement and verification protocol that includes methodologies for verifying the results of energy efficiency projects.

(e) A program, Superior Energy Performance, that will offer ANSI-accredited certification for energy efficiency through application of ANSI/MSE 2000:2008 and documentation of a specified improvement in energy performance using the ANSI measurement and verification protocol.

The complementary documents described above, when used together, will assist organizations seeking to establish and implement company-wide or site-wide energy plans.

ASME EA-3–2009 was approved by the EA Industrial System Energy Assessment Standards Committee on October 1, 2009 and approved by the American National Standards Institute (ANSI) on December 2, 2009.



EA INDUSTRIAL SYSTEM ENERGY ASSESSMENT STANDARDS COMMITTEE

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

F. P. Fendt, *Chair*
P. E. Sheaffer, *Vice Chair*
R. L. Crane, *Secretary*

STANDARDS COMMITTEE PERSONNEL

J. A. Almaguer, The Dow Chemical Co.	A. T. McKane, Lawrence Berkeley National Laboratory
R. D. Bessette, Council of Industrial Boiler Owners	W. A. Meffert, Georgia Institute of Technology
R. L. Crane, The American Society of Mechanical Engineers	J. L. Nicol, Science Applications International Corp.
G. T. Cunningham, Tennessee Tech University	J. D. Rees, North Carolina State University
T. J. Dunn, Weyerhaeuser Co.	P. E. Scheihing, U.S. Department of Energy
F. P. Fendt, The Dow Chemical Co.	P. E. Sheaffer, Resource Dynamics Corp.
A. R. Ganji, San Francisco State University	V. C. Tutterow, Project Performance Corp.
J. C. Ghislain, Ford Motor Co.	L. Whitehead, Tennessee Valley Authority
T. A. Gunderzik, XCEL Energy	A. L. Wright, Oak Ridge National Laboratory
S. J. Korellis, <i>Contributing Member</i> , Electric Power Research Institute	R. G. Wroblewski, Productive Energy Solutions, LLC

PROJECT TEAM EA-3 – ENERGY ASSESSMENT FOR STEAM SYSTEMS

A. L. Wright, <i>Chair</i> , Oak Ridge National Laboratory	F. P. Fendt, The Dow Chemical Co.
G. Harrell, <i>Vice Chair</i> , Energy Management Services	G. Hahn, Spirax Sarco
R. J. Jendrucko, <i>Vice Chair</i> , Consultant	G. M. Halley, American Boiler Manufacturer Association
P. E. Sheaffer, <i>Secretary</i> , Resource Dynamics Corp	N. Iordanova, Armstrong Service, Inc.
W. R. Behr, Consultant	G. McCoy, Washington State University
D. M. Bloom, Nalco Co.	R. A. Papar, Hudson Technologies Co.
C. R. Bozzuto, Consultant	W. L. Wells, LyondellBasell
S. Connor, Cleaver Brooks	



CORRESPONDENCE WITH THE EA COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to:

Secretary, EA Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the EA Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the EA Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his request in the following format:

- Subject:** Cite the applicable paragraph number(s) and a concise description.
- Edition:** Cite the applicable edition of the Standard for which the interpretation is being requested.
- Question:** Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The EA Committee holds meetings or telephone conferences, which are open to the public. Persons wishing to attend any meeting or telephone conference should contact the Secretary of the EA Standards Committee.



ENERGY ASSESSMENT FOR STEAM SYSTEMS

1 SCOPE AND INTRODUCTION

1.1 Scope

This Standard covers steam systems that are defined as a system containing steam generator(s) or other steam source(s), a steam distribution network and end-use equipment. Cogeneration and power generation components may also be elements of the system (gas turbines, backpressure steam turbines, condensing steam turbines). If steam condensate is collected and returned, the condensate return subsystem is a part of the steam system.

This Standard sets the requirements for preparing for, conducting, and reporting the results of a steam system energy assessment (hereafter referenced as an “assessment”) that considers the entire system, from energy inputs to the work performed as the result of these inputs. An assessment complying with this Standard need not address each individual system component or specific system within an industrial facility with equal weight; however, it shall be sufficiently comprehensive to identify the major opportunities for improving the overall energy performance of the steam system. This Standard is designed to be applied primarily at industrial facilities, but most of the specified procedures can be used in other facilities such as those in the institutional and commercial sectors.

The scope of work shall be to complete a comprehensive assessment on a steam system. In the case of an exceptionally large facility, it may be desirable to focus on only one of several steam systems. As a result, the assessment plan should be developed for this specific system only. If an energy stream derives from or is directed to an adjacent system (possibly in an adjacent energy-supplying or receiving facility), then the details of the energy streams (e.g., electricity, steam, natural gas) shall be considered as part of the assessment of the target system.

Assessments involve collecting and analyzing data on system design, operation, energy use, and performance, and identifying energy performance improvement opportunities for system optimization. An assessment may also include recommendations for improving resource utilization, reducing per unit production cost, reducing life cycle costs, and improving environmental performance related to the assessed system(s). Assessment activities shall include but are not limited to engaging facility personnel and providing information about the assessment process;

collecting and analyzing data on system design, operation, energy use, and performance; identifying energy performance improvement opportunities and making recommendations for system improvement and energy-saving project implementation in a written report. This report shall document system design; quantify energy operation and performance data; document the assessment process; show results, recommendations and savings projections; and improve the plant or facility personnel’s understanding of steam system energy use and operation.

This Standard sets requirements for:

- (a) organizing and conducting a steam system assessment
- (b) analyzing the data from the assessment
- (c) reporting and documentation of assessment findings

When contracting for assessment services, plant personnel may use the Standard to define and communicate their desired scope of assessment activity to third party contractors or consultants.

1.2 Limitations

This Standard does not provide guidance on how to perform a steam system assessment, but sets the requirements that need to be performed during the assessment. For additional assistance, see the companion *ASME Guide for ASME EA-3-2009 Energy Assessment for Steam Systems* on how to apply this Standard.

(a) This Standard does not specify how to design a steam system.

(b) This Standard does not specify the qualifications and expertise required of the person using the Standard.

(c) This Standard does not specify how to implement the recommendations developed during the assessment, but does include recommendations for implementation activities.

(d) This Standard does not specify how to measure and validate the energy savings that result from implementing assessment recommendations.

(e) This Standard does not specify how to calibrate test equipment used during the assessment.

(f) This Standard does not specify how to estimate the implementation cost or conduct financial analysis for recommendations developed during the assessment.

(g) This Standard does not specify specific steps required for safe operation of equipment during the assessment. The plant personnel in charge of normal operation of the equipment are responsible for ensuring that it is operated safely during the data collection phase of the assessment.

