

ASME B73.1-2012

**[Revision and Consolidation of ASME B73.1-2001 (R2007)
and ASME B73.5M-1995 (R2007)]**

Specification for Horizontal End Suction Centrifugal Pumps for Chemical Process

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Copyright © 2013 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



INTENTIONALLY LEFT BLANK



ASME B73.1-2012
[Revision and Consolidation of ASME B73.1-2001 (R2007)
and ASME B73.5M-1995 (R2007)]

Specification for Horizontal End Suction Centrifugal Pumps for Chemical Process

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Copyright © 2013 by the American Society of Mechanical Engineers.
No reproduction may be made of this material without written consent of ASME.



Date of Issuance: October 11, 2013

This Standard will be revised when the Society approves the issuance of a new edition. There will be no written interpretations of the requirements of this Standard issued to this edition.

Periodically certain actions of the ASME B73 Committee may be published as Cases. Cases are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2013 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.



CONTENTS

Foreword	v
Committee Roster	vii
Correspondence With the B73 Committee	viii
1 Scope	1
2 References	1
3 Alternative Designs	5
4 Nomenclature and Definitions	6
4.1 Definitions of Terms	6
4.2 Additional Definitions	6
5 Design and Construction Features for Metallic Pumps	6
5.1 Pressure and Temperature Limits	6
5.2 Flanges	6
5.3 Casing	6
5.4 Impeller	7
5.5 Shaft	7
5.6 Shaft Sealing	8
5.7 Bearings, Lubrication, and Bearing Frame	11
5.8 Materials of Construction	12
5.9 Corrosion Allowance	12
5.10 Direction of Rotation	12
5.11 Dimensions	12
5.12 Miscellaneous Design Features	12
6 Design and Construction Features for Thermoplastic and Thermoset Polymer Material Pumps	15
6.1 Pressure and Temperature Limits	15
6.2 Flanges	16
6.3 Casing	16
6.4 Impeller	17
6.5 Shaft	17
6.6 Shaft Sealing	17
6.7 Bearings, Lubrication, and Bearing Frame	17
6.8 Materials of Construction	20
6.9 Corrosion Allowance	20
6.10 Direction of Rotation	20
6.11 Dimensions	20
6.12 Miscellaneous Design Features	20
6.13 Inserts and Connecting Fasteners for Thermoplastic and Thermoset Polymer Material Pumps	21
7 General Information	21
7.1 Application	21
7.2 Tests and Inspections	24
7.3 Nameplates	25
8 Documentation	25
8.1 General	25
8.2 Requirements	25



8.3	Document Description	25
8.4	Specially Requested Documentation	28
Figures		
5.5.3-1	Shaft Sleeve Runout	7
5.6.2-1	Cylindrical Seal Chamber	8
5.6.2-2	Self-Venting Tapered Seal Chamber	9
5.6.2.1-1	Seal Chamber Face Runout	9
5.6.2.1-2	Seal Chamber Register Concentricity	9
5.6.3-1	Universal Cover	10
5.6.4-1	Packing Box	11
5.12.8-1	Pump With C-Face Motor Adapter, Short Coupled	16
6.6.3-1	Backplate With Seal Chamber	18
6.6.5-1	Backplate With Clamp Ring	19
8.3.1-1	Sample Outline Drawing	26
Tables		
1-1	Pump Dimensions	2
1-2	Baseplate Dimensions	4
5.8.1.2-1	Pump Material Classification Codes	13
5.8.1.3-1	ASTM Material Specifications	14
5.8.3.1-1	Minimum Requirements for Auxiliary Piping Materials	15
6.1.1.1-1	Thermoplastic and Thermoset Pump Minimum Design Pressures	16
7.1.5-1	Approximate Hydraulic Coverage, 50 Hz	22
7.1.5-2	Approximate Hydraulic Coverage, 60 Hz	23
7.1.6-1	Minimum Continuous Flow	24
Mandatory Appendices		
I	ASME Centrifugal Pump Data Sheet	29
II	Mechanical Seal and Packing Configuration Codes	34
Nonmandatory Appendix		
A	Electronic Data Exchange	36



FOREWORD

In 1955, the Standards Committee on Centrifugal Pumps for Chemical Industry Use, B73, undertook the development of centrifugal pump standards to meet the needs of the chemical industry. Although the Standards Committee had not completed its assignment, the work of one of its task forces resulted in the development of a de facto standard that was published by the Manufacturing Chemists Association in 1962 as an American Voluntary Standard (AVS). More than a dozen manufacturers of chemical process pumps marketed pumps conforming with the AVS.

In 1965, the Hydraulic Institute published a tentative standard similar in content to the AVS, but updated certain portions. Although the Hydraulic Institute Tentative Standard reflected more nearly the current practice of manufacturers and users, it was believed necessary to publish a new document that would supersede both the original AVS and the tentative standard, and that could incorporate the technical content of both documents and dimensional criteria and features generally accepted by manufacturers and users. The January 1968 revision of the AVS was therefore approved as an American National Standard under the existing standards method and published as ANSI B123.1-1971.

ANSI B73.1 superseded ANSI B123.1-1971 and was first published in 1974. The 1974 edition brought to 15 the number of pump sizes covered by the standard. The committee continued to be active, adding 5 more sizes for a total of 20, and making a number of revisions in the text of the standard.

Shortly thereafter, the American National Standards Committee B73 undertook to revise the standard, and, as a result, new information on baseplate rigidity, bearing frame adapter, and bearing housing drain was introduced. The 1984 edition included, for the first time, information that covered documentation of the pump and driver outline drawing of the centrifugal pump, data sheet, mechanical seal drawing, packing box piping plans, and cooling/heating piping plans.

The 1991 revision included larger and self-venting tapered seal chambers, as well as conventional packing boxes; revised baseplate dimensions, with a new identification numbering system; and a ductile material requirement for the bearing frame adapter if it clamps the rear cover plate to the casing.

With the expanding utilization of the ASME B73.1 pumps in the chemical process industry and its growing acceptance in the hydrocarbons processing industry, the B73 committee continued to improve the B73.1 standard. The 2001 revision of the standard incorporated 7 new sizes of pumps, bringing the total number to 27. Many of the new additions were at the request of the user population. Inclusion of ISO standard size pumps was considered by the committee. It was consensus that the ISO inclusion would have made the B73.1 standard overly complex and weakened its mechanical fortitude. Thus, this action was rejected by the committee. The "Materials of Construction" section of the standard was expanded to include readily available corrosion-resistant alloys. Recent publications by the Hydraulic Institute in areas such as baseplate tolerance, acceptable nozzle loads, preferred operating region, and NPSH margin were incorporated into this revision. A standardized electronic data exchange file specification was established as an integral portion of the standard. This was, in part, in response to the needs of the user community for compliance to U.S. government regulations covering chemical process equipment and pumps, specifically OSHA Process Safety Management, 29 CFR 1910.119. In total, these revisions to the standard were intended to better serve process industries and expand the use of ASME B73 pumps worldwide.

The 2012 revision of the standard includes several changes to reduce redundancy in the B73 set of standards and to better align with the Hydraulic Institute (HI) and American Petroleum Institute (API) pump standards. Revisions have also been made to further improve the reliability of the B73.1 pumps. ASME standard B73.5 on solid polymer pumps has been merged into B73.1 due to the many similarities of the two standards. B73.5 will be withdrawn. Reference is now made to API practices for mechanical seal configurations and cooling and heating plans. A



mechanical seal configuration code and a material classification code have been added to B73.1. A universal cover has been added to the standard as an alternate sealing cover. Requirements for the bearing frame have been revised to assure more robust pumps. C-face motor adapters are now an option. The default performance test acceptance grade has been revised to reflect the new HI/ISO performance test standard. More detail has been added to the required drawings, curve, and documentation that should be included with the pump. A new data sheet has been developed and added to the standard. The standard endorses the electronic data exchange standard that was developed by the Hydraulic Institute and Fiatch Automating Equipment Information Exchange (AEX) project.

Suggestions for improvement of this Standard are welcome. They should be sent to The American Society of Mechanical Engineers; Attn: Secretary, B73 Committee; Two Park Avenue, New York, NY 10016-5990.

This revision was approved as an American National Standard on November 14, 2012.



ASME B73 COMMITTEE

Chemical Standard Pumps

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

K. R. Burkhardt, *Chair*
R. W. Estep, *Vice Chair*
C. J. Gomez, *Secretary*

STANDARDS COMMITTEE PERSONNEL

E. W. Allis , Consultant	G. S. Highfill , Wilfley & Sons, Inc.
K. R. Burkhardt , DuPont	M. B. Huebner , Flowserve Corp.
G. C. Clasby , Flowserve Corp., Flow Solutions Group	I. S. James , Best PumpWorks
C. K. van der Sluijs , <i>Alternate</i> , Flowserve Corp., Flow Solutions Group	B. S. Myers , Bayer CropScience
M. Coussens , Peerless Pump Co.	G. W. Sabol , Lyondell Chemical Co.
J. F. Dolniak , NIPSCO	K. A. Strautman , <i>Alternate</i> , Lyondell Chemical Co.
R. W. Estep , The Dow Chemical Co.	B. K. Schnelzer , Met-Pro Corp., Dean Pump Division
C. J. Gomez , The American Society of Mechanical Engineers	W. W. Parry , <i>Alternate</i> , Met-Pro Global Pump Solutions
	A. E. Stavale , ITT Goulds Pumps



CORRESPONDENCE WITH THE B73 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by proposing revisions and attending Committee meetings. Correspondence should be addressed to:

Secretary, B73 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard, the paragraph, figure or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Attending Committee Meetings. The B73 Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the Secretary of the B73 Standards Committee.



SPECIFICATION FOR HORIZONTAL END SUCTION CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS

1 SCOPE

(a) This Standard is a design and specification standard that covers metallic and solid polymer centrifugal pumps of horizontal, end suction single stage, centerline discharge design. This Standard includes dimensional interchangeability requirements and certain design features to facilitate installation and maintenance and to enhance reliability and safety of B73.1 pumps. It is the intent of this Standard that pumps of the same standard dimension designation from all sources of supply shall be interchangeable with respect to mounting dimensions, size, and location of suction and discharge nozzles, input shafts, baseplates, and foundation bolt holes (see Tables 1-1 and 1-2). Maintenance and operation requirements are not included in this Standard.

(b) This Standard has been revised to include solid polymer pumps formerly covered under ASME B73.5. The design and construction features for metallic pumps are covered in section 5. The design and construction features for solid polymer pumps are covered in section 6. This Standard must be read in its entirety for proper application.

2 REFERENCES

The following documents form a part of this Standard to the extent specified herein. The latest edition shall apply.

ANSI B11.19, Performance Criteria for Safeguarding

Publisher: Association for Manufacturing Technology (AMT), 7901 Westpark Drive, McLean, VA 22102-4206 (www.amtonline.org)

ANSI/ABMA-9, Load Ratings and Fatigue Life for Ball Bearings

ANSI/ABMA-11, Load Ratings and Fatigue Life for Roller Bearings

Publisher: American Bearing Manufacturers Association (ABMA), 2025 M Street, NW, Washington, DC 20036 (www.abma-dc.org)

ANSI/HI 1.1-1.2, Rotodynamic (Centrifugal) Pumps for Nomenclature and Definitions

ANSI/HI 1.3, Rotodynamic (Centrifugal) Pumps for Design and Application

ANSI/HI 1.4, Rotodynamic (Centrifugal) Pumps for Manuals Describing Installation, Operation and Maintenance

ANSI/HI 9.1-9.5, Pumps — General Guidelines

ANSI/HI 9.6.1, Rotodynamic Pumps — Guideline for NPSH Margin

ANSI/HI 9.6.2, Rotodynamic Pumps for Assessment of Applied Nozzle Loads

ANSI/HI 9.6.4, Rotodynamic Pumps Vibration Measurements and Allowable Values

ANSI/HI 14.6, Rotodynamic Pumps for Hydraulic Performance Acceptance Tests

Publisher: Hydraulic Institute (HI), 6 Campus Drive, Parsippany, NJ 07054 (www.pumps.org)

API Std 610, Centrifugal Pumps for Petroleum, Petrochemical and Natural Gas Industries

API Std 682, Pumps — Shaft Sealing Systems for Centrifugal and Rotary Pumps

Publisher: American Petroleum Institute (API), 1220 L Street, NW, Washington, DC 20005 (www.api.org)

ASME B16.5, Pipe Flanges and Flanged Fittings

ASME B16.11, Forged Steel Fittings, Socket-Welding and Threaded

ASME B16.42, Ductile Iron Pipe Flanges and Flanged Fittings: Classes 150 and 300

Publisher: The American Society of Mechanical Engineers (ASME), Two Park Avenue, New York, NY 10016-5990; Order Department: 22 Law Drive, P.O. Box 2900, Fairfield, NJ 07007-2900 (www.asme.org)

ASTM A48/A48M, Standard Specification for Gray Iron Castings

ASTM A105/A105M, Standard Specification for Carbon Steel Forgings for Piping Applications

ASTM A106/A106M, Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service

ASTM A108, Standard Specification for Steel Bar, Carbon and Alloy, Cold-Finished

ASTM A182/A182M, Standard Specification for Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service

