

ASME B16.23-2016
(Revision of ASME B16.23-2011)

Cast Copper Alloy Solder Joint Drainage Fittings: DWV

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME B16.23-2016
(Revision of ASME B16.23-2011)

Cast Copper Alloy Solder Joint Drainage Fittings: DWV

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: January 16, 2017

The next edition of this Standard is scheduled for publication in 2021.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME B16 Committee may be published as Cases. Cases and interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting “Errata” in the “Publication Information” section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2016 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	v
Committee Roster	vii
Correspondence With the B16 Committee	viii
Summary of Changes	x
List of Changes in Record Number Order	xi
1 Scope	1
2 General	1
3 Description	1
4 Pitch (Slope)	1
5 Abbreviations	1
6 Size	1
7 Marking	2
8 Material	2
9 Metal Thickness	2
10 Inspection Tolerance	2
11 Threaded Ends	2
12 Configuration of Threaded Ends	3
Figures	
1 Typical Laying Lengths of DWV 90-deg Elbows	4
2 Size Sequence of Fittings	4
Tables	
1 Inspection Tolerance Table	4
2 Dimensions of Solder Joint Ends — DWV	5
3 Dimensions of Threaded Ends — DWV	6
4 Dimensions of DWV Couplings, Reducers, Extended Bushings, and Flush Bushings	7
5 Dimensions of DWV Adapters	8
6 Dimensions of DWV Short Adapters	9
7 Dimensions of DWV Trap Adapters	9
8 Dimensions of C to Soil Pipe Adapter for Joining to Extra Heavy Soil Pipe	10
9 Dimensions of C to Soil Pipe Adapter — Plain End for Joining to Extra Heavy Soil Pipe	11
10 Dimensions of C × No-Hub Soil Pipe Adapter	12
11 Dimensions of C × Hub Soil Pipe Adapter	13
12 Dimensions of DWV 45-deg Y With Cleanout — Soil Pipe (Spigot) × C × Cleanout	13
13 Dimensions of DWV Elbows and Double Elbows — C × C	14
14 Dimensions of Reducing DWV Single and Double Elbows — C × C	15
15 Dimensions of DWV Elbows	16
16 Dimensions of DWV Reducing Elbows	17
17 Dimensions of DWV Elbows	17
18 Dimensions of DWV Tees and Double Tees	18

19	Dimensions of DWV Tees and Double Tees	19
20	Dimensions of DWV Trap Tees	20
21	Dimensions of DWV Double and Quadruple Branch Fittings	20
22	Dimensions of Short Design DWV Tees With Side Inlet(s) (90 deg to Main Inlet), Single and Double	20
23	Dimensions of Short Design DWV Tees With Side Inlet(s) (45 deg to Main Inlet), Single and Double	21
24	Dimensions of Long Design DWV Tees With Side Inlet(s) (90 deg to Main Inlet), Single and Double	21
25	Dimensions of Long Design DWV Tees With Side Inlet(s) (45 deg to Main Inlet), Single and Double	22
26	Dimensions of Single and Double DWV 45-deg Ys	23
27	Dimensions of DWV 45-deg Ys	24
28	Dimensions of DWV Horizontal Twin Branch Tees	24
29	Dimensions of DWV Fitting Tees, Single and Double	24
30	Dimensions of DWV Utility Tees	25
31	Dimensions of DWV Fitting Tees With Side Inlet Maximum Below Centerline	26
32	Dimensions of DWV Long Turn T-Ys, Single and Double	27
33	Dimensions of DWV Double Short T-Y (C × C × F × F)	28
34	Dimensions of DWV Double Short T-Y (C × C × C × C)	28
35	Dimensions of DWV Elbow With Inlets	28
36	Dimensions of DWV Double Branch Sink Fittings	29
37	Dimensions of DWV Closet Offset Fittings	29
38	Dimensions of DWV 90-deg Closet Elbow	30
39	Dimensions of Floor Flange Vent Support	30
40	Dimensions of DWV Closet Ells With Side Inlet(s) (90 deg and 45 deg) to Main Inlet(s)	31
41	Dimensions of DWV Closet Ells With or Without Side Inlet(s) (90 deg and 45 deg) to Main Inlet(s)	32
42	Dimensions of DWV Closet Flanges	33
43	Dimensions of Vent Tees and Vent Double Tees	34
44	Dimensions of Vent Elbows	34
45	Dimensions of DWV Stack Upturns, Single and Double	34
46	Dimensions of Slip Joint Pieces	35
47	Dimensions of Trap Coupling	35
48	Dimensions of Trap Extended Bushings	35
49	Dimensions of Slip Joint Ends	36
50	Dimensions of DWV Cap	36
51	Dimensions of DWV Plugs	36
52	Dimensions of DWV Drum Traps	37
53	Dimensions of DWV Swivel Drum Traps	38
54	Dimensions of DWV Traps	39
55	Dimensions of DWV Test Tees With Plug	40
56	Dimensions of DWV Plugs	40

Mandatory Appendices

I	U.S. Customary Tables	41
II	References	78

Nonmandatory Appendix

A	Quality System Program	79
---	------------------------------	----

FOREWORD

Standardization work on solder joint fittings began in 1936 in Subcommittee 11 of Sectional Committee A40, Minimum Requirements for Plumbing and Standardization of Plumbing Equipment, organized within the American Standards Association (ASA). It resulted in the publication, in January 1941, of ASA A40.3-1941. That standard covered only supply (pressure) fittings.

In 1949, responsibility for solder joint fittings was transferred to newly formed Subcommittee 9 of Sectional Committee B16 on Standardization of Pipe Flanges and Fittings. The next revision of A40.3 appeared as ASA B16.18-1950, Cast-Brass Solder-Joint Fittings. During its development, however, the need for separate standards for wrought copper and wrought bronze supply fittings and for solder joint drainage fittings was recognized.

Work on the wrought fitting standard was undertaken by a joint committee of the Copper and Brass Research Association and the Manufacturers' Standardization Society of the Valve and Fittings Industry (MSS). That work, properly reviewed and approved, was published as ASA B16.22-1951.

Concurrently, in June 1949, at the request of Subcommittee 9, a task group organized by MSS began work on a standard for cast brass solder joint drainage fittings. Representatives of all U.S. and Canadian manufacturers were invited to participate. The Report of the Coordinating Committee for a National Plumbing Code was taken into account; special research on wall thickness and depth of solder joint was conducted; and coordination with other standards was sought, to avoid inconsistency. After working through nine drafts to reach consensus, the group submitted an April 1952 draft to Subcommittee 9. After committee, sponsor, and ASA approval, the standard was approved as ASA B16.23-1953, Cast Brass Solder Joint Drainage Fittings, on January 30, 1953.

Work soon began on a revision, to include additional sizes, reducing sizes, and additional types of fittings. A March 1955 draft was approved by the B16 Committee, sponsors, and ASA, and published as ASA B16.23-1955. Starting in 1958, responding to requests for further revision and expansion, the MSS task group developed a 1959 draft that was approved by Subcommittee 9, the B16 Committee, sponsors, and ASA, and was published as ASA B16.23-1960.

In 1967 and 1968, a complete revision was undertaken, including engineering studies to verify that a user request for shorter soldering cups was justified. The resulting draft, after approval by Subcommittee 9, USA Standards Committee B16, sponsors, and the (then-called) USA Standards Institute, was published as USAS B16.23-1969. An addenda, dated 1973, lengthened the cups on the three smallest sizes to overcome assembly problems.

The subcommittee, now Subcommittee I, began a new revision in 1974, resulting in the inclusion of the 1973 addenda, addition of metric equivalents, and change of "bronze" to "copper alloy." The draft, finally approved by the (again renamed) American National Standards Institute (ANSI), was published as ANSI B16.23-1976.

In 1982, a new edition updating dimensional tables and metric equivalents was developed. Following approval at all levels, the revision was published as ANSI B16.23-1984.

Also in 1982, American National Standards Committee B16 became the ASME B16 Standards Committee, operating with the same scope, under ASME procedures accredited by ANSI. Subsequently, Subcommittee I merged with Subcommittee J, which had a related scope.

The 1992 edition removed metric units, establishing U.S. Customary units as the standard. Clarifications and updating changes were made to improve the text. The 2002 edition of B16.23 added SI units of measure in the main body of text and moved U.S. Customary units to Mandatory Appendix I. A Nonmandatory Appendix for Quality System Programs was added, plus editorial changes were made to improve text. Following approval by the Standards Committee and ASME, approval as an American National Standard was given on February 6, 2002, with the designation, ASME B16.23-2002.

In the 2011 edition, references to ASME standards were revised to no longer list specific edition years. Following approval by the Standards Committee and the ASME Board on PTCS, the revision to the 2002 edition was approved as an American National Standard by ANSI on September 23, 2011 with the new designation, ASME B16.23-2011.

In this 2016 edition, provisions have been made to update verbiage and readings. Following the approval by the ASME B16 Standards Committee, approval as an American National Standard was given by ANSI on October 21, 2016, with the new designation ASME B16.23-2016.

ASME B16 COMMITTEE

Standardization of Valves, Flanges, Fittings, and Gaskets

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

R. M. Bojarczuk, *Chair*
C. E. Davila, *Vice Chair*
C. Ramcharran, *Secretary*

STANDARDS COMMITTEE PERSONNEL

A. Appleton , Alloy Stainless Products Co., Inc.	M. Katcher , Haynes International
J. E. Barker , Dezurik Water Controls	T. A. McMahon , Emerson Process Management
R. W. Barnes , Anric Enterprises, Inc.	M. L. Nayyar , NICE
K. Barron , Ward Manufacturing	W. H. Patrick , The Dow Chemical Co.
D. C. Bayreuther , Metso Automation, Flow Control Division	D. Rahoi , Consultant
W. B. Bedesem , Consultant	C. Ramcharran , The American Society of Mechanical Engineers
R. M. Bojarczuk , ExxonMobil Research and Engineering Co.	R. A. Schmidt , Canadoil
A. M. Cheta , Qatar Shell GTL	J. Tucker , Flowserve
M. A. Clark , NIBCO, Inc.	F. R. Volgstadt , Volgstadt & Associates, Inc.
G. A. Cuccio , Capitol Manufacturing Co.	P. Milankov , <i>Alternate</i> , Consultant
J. D'Avanzo , Fluoroseal Valves	F. Feng , <i>Delegate</i> , China Productivity Center for Machinery
C. E. Davila , Crane Energy	P. V. Craig , <i>Contributing Member</i> , Jomar Group
D. R. Frikken , Becht Engineering Co.	B. F. Fabian , <i>Contributing Member</i> , Pennsylvania Machine Works
R. B. Hai , RBH Associates	A. G. Kireta, Jr. , <i>Contributing Member</i> , Copper Development Association, Inc.
G. A. Jolly , Consultant	D. F. Reid , <i>Contributing Member</i> , VSP Technologies

SUBCOMMITTEE J — COPPER AND COPPER ALLOY FLANGES, FLANGED FITTINGS, AND SOLDER JOINT FITTINGS

A. G. Kireta, Jr. , <i>Chair</i> , Copper Development Association, Inc.	T. L. Jamison , Jamison Engineering
M. A. Clark , <i>Vice Chair</i> , NIBCO, Inc.	A. A. Knapp , A. Knapp & Associates
E. Lawson , <i>Secretary</i> , The American Society of Mechanical Engineers	C. A. Mueller , Mueller Industries, Inc.
J. A. Ballanco , JB Engineering and Code Consulting PC	F. Shingleton , Viega, LLC
S. L. Cavanaugh , Cavanaugh Consulting	G. Morgan , <i>Alternate</i> , Viega, LLC
W. E. Chapin , Professional Code Consulting, LLC	S. Blair , <i>Contributing Member</i> , Cerro Flow Products, LLC
D. R. Frikken , Becht Engineering Co.	M. Gillespie , <i>Contributing Member</i> , Viega, LLC

CORRESPONDENCE WITH THE B16 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, B16 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the B16 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the B16 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/InterpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may e-mail the request to the Secretary of the B16 Standards Committee at SecretaryB16@asme.org, or mail it to the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

Subject:	Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
Edition:	Cite the applicable edition of the Standard for which the interpretation is being requested.
Question:	Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a "yes" or "no" reply is acceptable.
Proposed Reply(ies):	Provide a proposed reply(ies) in the form of "Yes" or "No," with explanation as needed. If entering replies to more than one question, please number the questions and replies.
Background Information:	Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The B16 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the B16 Standards Committee.

ASME B16.23-2016

SUMMARY OF CHANGES

Following approval by the ASME B16 Committee and ASME, and after public review, ASME B16.23-2016 was approved by the American National Standards Institute on October 21, 2016.

ASME B16.23-2016 includes the following change identified by a margin note, **(16)**. The Record Numbers listed below are explained in more detail in "List of Changes in Record Number Order" following this Summary of Changes.

<i>Page</i>	<i>Location</i>	<i>Change (Record Number)</i>
1	1	In first paragraph, last line revised (12-606)
6	Table 3	Notes (3) and (4) revised (12-606)
43	Table I-3	Notes (3) and (4) revised (12-606)
78	Mandatory Appendix II	Revised (16-1574)

LIST OF CHANGES IN RECORD NUMBER ORDER

Record Number	Change
12-606	Revised Scope, Table footnotes, and Mandatory Appendix II
16-1574	Updated Mandatory Appendix II References

INTENTIONALLY LEFT BLANK

CAST COPPER ALLOY SOLDER JOINT DRAINAGE FITTINGS: DWV

(16) 1 SCOPE

This Standard establishes specifications for cast copper alloy solder joint drainage fittings, designed for use in drain, waste, and vent (DWV) systems. These fittings are designed for use with seamless copper tube conforming to ASTM B306, Copper Drainage Tube (DWV), as well as fittings intended to be assembled with soldering materials conforming to ASTM B32, or tapered pipe thread conforming to ASME B1.20.1.

This Standard is allied with ASME B16.29, Wrought Copper and Wrought Copper Alloy Solder Joint Drainage Fittings — DWV.

It provides requirements for fitting ends suitable for soldering. This Standard covers

- (a) description
- (b) pitch (slope)
- (c) abbreviations for end connections
- (d) sizes and methods for designing openings for reducing fittings
- (e) marking
- (f) material
- (g) dimensions and tolerances

2 GENERAL

2.1 Relevant Units

This Standard states values in both SI (Metric) and U.S. Customary units. These systems of units are to be regarded separately as standard. Within the text, the U.S. Customary units are shown in parentheses or in separate tables that appear in Mandatory Appendix I. The values stated in each system are not exact equivalents; therefore, it is required that each system of units be used independently of the other. Combining values from the two systems constitutes nonconformance with the Standard.

2.2 References

Standards and specifications adopted by reference in this Standard are shown in Mandatory Appendix II, which is part of this Standard. It is not considered practical to identify the specific edition of each standard and specification in the individual references. Instead, the specific edition reference is identified in Mandatory Appendix II.

2.3 Quality Systems

Requirements relating to the product manufacturer's quality system programs are described in Nonmandatory Appendix A.

3 DESCRIPTION

(a) These fittings are designed for drainage and vent systems using the solder joint method of connection. The fitting cups (C), are provided with stops so that the ends of the tube, when assembled, meet the stops, thereby forming essentially smooth passageways.

(b) The sketches and designs of fittings are illustrative only. The dimensions specified herein shall govern in all cases.

4 PITCH (SLOPE)

All nominal 90-deg fittings shall be pitched to result in a slope of 21 mm/m (0.25 in./ft) (2.1%) of length of horizontal tube with reference to a horizontal plane (see Fig. 1).

5 ABBREVIATIONS

The following symbols are used to designate the type of fitting end:

- C = solder-joint fitting end made to receive copper tube diameter (female)
- F = internal ANSI Standard taper pipe thread (female) NPT
- FTG = solder-joint fitting end made to copper tube diameter (male)
- M = external ANSI Standard taper pipe thread (male) NPT
- NPSM = standard straight mechanical pipe thread
- SJ = end of fitting made to receive O.D. tube size

6 SIZE

(a) The size of the fittings scheduled in Tables 1 through 56 and Tables I-1 through I-56 corresponds to the drainage tube size shown in ASTM B306. The size of the threaded ends (except slip joints) corresponds to the nominal pipe size.