

American National Standard

ASSE 1051-2021



Performance Requirements for
**Individual and Branch Type Air
Admittance Valves for Sanitary
Drainage Systems**

ASSE Board Approved: June 2021

ANSI Approved: July 2021

ICS Codes: 91 140 80



General Information

Neither this document, nor any portion thereof, may be reproduced without the written consent of ASSE International.

No product may be said to be ASSE listed unless the manufacturer has applied to ASSE International, has had the product tested by an official ASSE recognized independent laboratory, according to the applicable ASSE standard, passed the test, and has been reviewed and approved by the consensus ASSE International Seal Control Board. Having completed the aforementioned, the manufacturer may then display the ASSE Seal on the product.

Instructions for receiving the authorization to display the Seal are available from the ASSE International Office. Organizations wishing to adopt or list any ASSE standard should print the ASSE standard number on the cover page first and in equal or larger type to that of the adopting or listing organization.

ASSE International
Mokena, Illinois
Copyright © 2021, 2009
All rights reserved.

Foreword

This foreword shall not be considered a part of the standard; however, it is offered to provide background information.

ASSE standards are developed in the interest of consumer safety.

ASSE International considers product performance standards to be of great value in the development of improved plumbing systems.

The working group that developed this standard was set up within the framework of the Product Standards Committee of ASSE International.

An AAV is a one-way valve designed to allow air to enter the plumbing drainage system when a negative pressure develops in the piping. The device shall be closed at zero differential pressure and under conditions of positive internal pressure.

These devices are typically installed after a building drainage system has been tested and inspected for pipe leaks. Installing these devices prior to that would damage them during the building's test.

See ASSE Standard #1050-2021 for the Performance Requirements for Stack Air Admittance Valves for Sanitary Drainage Systems.

The working group that developed this standard was set up within the framework of the Product Standards Committee of ASSE International.

Recognition is made of the time volunteered by members of this working group and of the support of manufacturers who also participated in meetings for this standard.

This standard does not imply ASSE International's endorsement of a product which conforms to these requirements.

Compliance with this standard does not imply acceptance by any code body.

It is recommended that these devices be installed consistent with local codes by qualified and trained professionals.

This standard was promulgated in accordance with the ASSE Procedures for Standards Development as approved by the American National Standards Institute (ANSI).

2021 Product Standards Committee

Tsan-Liang Su, PhD, Chairperson

*Stevens Institute of Technology
Hoboken, NJ*

Karl Abrahamson

*Saint Paul Department of Safety
and Inspections
Cottage Grove, MN*

Brian Andersen

*Plumbers' JAC LU130
Chicago, IL*

John Bertrand

*Watts Water Technologies
Cleveland, OH*

Julia Briggs

*NSF International
Ann Arbor, MI*

William Briggs Jr.

*TSF Engineering
New York, NY*

Terry Burger (non-voting)

*ASSE International
Cleveland, OH*

William Chapin

*Professional Code Consulting, LLC
Cullman, AL*

Mark E. Fish

*Zurn Industries, LLC
Cary, NC*

Ron George

*Plumb-Tech Design & Consulting Services LLC
Newport, MI*

Mark Gibeault

*Kohler Company
Kohler, WI*

Daniel Gleiberman

*Sloan Valve Company
Los Angeles, CA*

Brandon Gunnell

*Precision Plumbing Products
Portland, OR*

Chris Haldiman

*Watts Water Technologies
Springfield, MO*

John F. Higdon, P.E.

*Supply Source Products
Matthews, NC*

Jim Kendzel

*American Supply Association
Minneapolis, MN*

Ramiro Mata

*ASPE
Mentor, OH*

Bob Neff

*Delta Faucet
Pendleton, IN*

David Orton

*NSF International
Ann Arbor, MI*

Thomas Pitcherello

*State of New Jersey
Bordentown, NJ*

Daniel Rademacher

*Viega, LLC
Butte, MT*

Shabbir Rawalpindiwala

*Kohler Company
Kohler, WI*

Billy Smith

*ASPE
Montgomery, AL*

Chris White (non-voting)

*ASSE International
Mokena, IL*

AAV Working Group (1049, 1050, 1051)

Joe Cavett

*QAI Labs
Tulsa, OK*

Steve Cole

*IPS Corp
Collierville, TN*

Hans Hansson

*AB Durgo
Stockholm, Sweden*

Elene Neel

*Frajon Valves
Indian Land, SC*

Dave Orton

*NSF International
Ann Arbor, MI*

Timothy M. Reising Sr. (non-voting)

*ASSE International
Mokena, IL*

Steve White

*Studor Ltd
East Sussex, United Kingdom*

Table of Contents

Section I	1
1.0 General	1
1.1 Application	1
1.2 Scope	1
Table 1	2
1.3 Construction	2
1.4 Reference Standards	3
Section II	4
2.0 Test Specimens and Test Laboratory	4
Section III	5
3.0 Performance Requirements and Compliance Testing	5
3.1 Pressure Test of the Complete Device	5
Figure 1	6
3.2 Rating and Opening Pressure Test	6
Figure 2	7
3.3 Endurance Test	8
Figure 3	8
Section IV	10
4.0 Detailed Requirements	10
4.1 Materials	10
4.2 Instructions for Marking and Installation	10
Section V	12
5.0 Definitions	12

Performance Requirements for Individual and Branch Type Air Admittance Valves for Sanitary Drainage Systems

Section I

1.0 General

1.1 Application

Individual and Branch Type Air Admittance Valves (AAVs) for Sanitary Drainage Systems (herein referred to as “device”) are devices used in plumbing drainage systems to prevent the siphonage of water trap seals. These devices do not relieve back pressure; they only allow air to enter the system. These devices are designed to be used for individual fixtures or for a horizontal branch serving multiple fixtures. When these devices are installed in a building, there shall be at least one (1) open vent terminal to relieve positive pressure which extends to the atmosphere outside of the building serving the building drain on which these devices are installed.

1.2 Scope

1.2.1 Description

These devices consist of a one-way valve designed to allow air to enter the plumbing drainage system when a pressure less than atmospheric develops. The device closes and seals by gravity under zero (0) differential pressure (static condition) and under positive pressure. These devices prevent sewer gases from entering a building. The device consists of a hooded or shielded body which contains a normally closed movable sealing assembly which seats and seals air flow when closed and allows air to enter when open.

1.2.2 Temperature Range

These devices shall function at temperatures from -40.0 °F to 150.0 °F (-40.0 °C to 65.6 °C).

1.2.3 Rating

These devices shall, at a minimum, pass the air flow rate according to Table 1 at -1.0 inch (-25.4 mm) water column.

Note: This corresponds to half the size of a 2-inch (50.8mm) trap diameter for when a trap potentially evaporates.