



PROCESS
INDUSTRY
PRACTICES

TECHNICAL REVISION
July 2022

Process Control

PIP PCCFL001
Flow Measurement Design Criteria

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

| | | | |
|---------------------|--------------------------|------------------|---------------------------|
| <i>June 1998</i> | <i>Issued</i> | <i>July 2022</i> | <i>Technical Revision</i> |
| <i>August 2006</i> | <i>Complete Revision</i> | | |
| <i>October 2015</i> | <i>Complete Revision</i> | | |

Not printed with State funds



PIP PCCFL001

Flow Measurement Design Criteria

Table of Contents

| | | | |
|--|----------|---|----|
| 1. Scope | 2 | 3.12 Ultrasonic Meter (Transit Time & Doppler)..... | 10 |
| 2. References..... | 2 | 3.13 Clamp-on Ultrasonic Meter..... | 11 |
| 2.1 Process Industry Practices..... | 2 | 3.14 Vortex Meter | 11 |
| 2.2 Industry Codes and Standards..... | 2 | 3.15 Variable Area Meter..... | 11 |
| 2.3 Other References | 3 | 3.16 Wedge Type Meter | 11 |
| 3. Requirements | 3 | 3.17 V-Cone Meter | 12 |
| 3.1 General | 3 | 3.18 Impact Plate Meter | 12 |
| 3.2 Orifice Meter | 6 | | |
| 3.3 Flow Nozzle | 7 | | |
| 3.4 Venturi (Classical and Proprietary Designs)..... | 8 | | |
| 3.5 Averaging Pitot Element..... | 8 | | |
| 3.6 Integral Orifice | 9 | | |
| 3.7 Turbine Meter | 9 | | |
| 3.8 Positive Displacement Meter..... | 9 | | |
| 3.9 Magnetic Flow Meter | 10 | | |
| 3.10 Mass Meter (Coriolis) | 10 | | |
| 3.11 Mass Meter (Thermal) | 10 | | |

Tables

| | |
|--|----|
| Table 1: Minimum Straight Run Lengths for Orifice Runs and Other Flow Elements in Accordance with ISO 5167-2 Column B..... | 13 |
| Table 2: Minimum Straight Run Lengths for Orifice Runs in Accordance with ANSI/API (ISO 5167-2, Column A) | 14 |
| Table 3: Minimum Straight Run Lengths for Venturi Nozzles and Flow Nozzles in Accordance with ANSI/API (ISO 5167-3) | 15 |

1. Scope

This Practice describes the design requirements for flow measurement systems that include head (differential pressure), velocity, oscillatory, electromagnetic and mass flow meters.

This Practice does not cover:

- a. Restriction flow elements and flow switches
- b. Process isolation (root) valves, secondary transmitters, or process piping
- c. Custody transfer measurement requirements

2. References

Applicable parts of the following Practices, industry codes and standards, and references shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP PCCGN001 - *General Instrument Design Basis*
- PIP PCCGN002 - *General Instrument Installation Criteria*
- PIP PCIDP000 - *Differential Pressure Installation Details*
- PIP PNF0200 - *Vents, Drains, and Instrument Connection Details*

2.2 Industry Codes and Standards

- American Gas Association (AGA)
- American National Standards Institute (ANSI)
 - ANSI-2530/API-14.3/AGA-3/GPA-8185 - *Natural Gas Fluids Measurement - Concentric, Square-Edged Orifice Meters*
 - Part 1 General Equations and Uncertainty Guidelines
 - Part 2 Specification and Installation Requirements
 - Part 3 Natural Gas Applications
 - Part 4 Background, Development, Implementation Procedures and Subroutine Documentation
- American Petroleum Institute (API)
 - *API Manual of Petroleum Measurement Standards (MPMS): Chapter 5 - Metering*
 - 5.2 *Measurement of Liquid Hydrocarbons by Displacement Meters*
 - 5.3 *Measurement of Liquid Hydrocarbons by Turbine Meters*
- American Society of Mechanical Engineers (ASME)
 - ASME B16.36 - *Orifice Flanges*
 - ASME MFC-3M - *Measurement of Fluid Flow in Pipes Using Orifice, Nozzle, and Venturi*